

## 泰州市水务有限公司出厂水全分析综合报表

采样地点:				城东增压站水 库	第二水厂新二 泵房	第三水厂送水 泵房
采样时间:				2023.9.5		
合格率:				100%	100%	100%
总合格率:				100%		
序号	检测项目	单位	生活饮用水水质卫生标准 (GB5749-2022)	检验结果		
1	总大肠菌群	MPN/100m	不应检出	未检出	未检出	未检出
2	大肠埃希氏菌	MPN/100m	不应检出	未检出	未检出	未检出
3	菌落总数	CFU/mL	≤100	<1	<1	<1
4	砷	mg/L	≤0.01	0.0018	0.0011	0.0010
5	镉	mg/L	≤0.005	<0.0001	<0.0001	<0.0001
6	铬(六价)	mg/L	≤0.05	<0.004	<0.004	<0.004
7	铅	mg/L	≤0.01	<0.001	<0.001	<0.001
8	汞	mg/L	≤0.001	<0.00010	<0.00010	<0.00010
9	氰化物	mg/L	≤0.05	<0.002	<0.002	<0.002
10	氟化物	mg/L	≤1.0	0.232	0.235	0.223
11	硝酸盐氮(以N计)	mg/L	≤10	1.99	1.98	1.96
12	三氯甲烷	mg/L	≤0.06	0.0079	0.0022	0.0042
13	溴酸盐	mg/L	≤0.01	<0.005	<0.005	<0.005
14	亚氯酸盐	mg/L	≤0.7	<0.05	<0.05	<0.05
15	氯酸盐	mg/L	≤0.7	<0.050	0.086	<0.050
16	色度	度	≤15	<5	<5	<5
17	浑浊度	NTU	≤1	0.06	0.08	0.07
18	臭和味	级	无异味,异臭	无(0级)	无(0级)	无(0级)
19	肉眼可见物		无	无	无	无
20	pH值		6.5~8.5	7.59	7.60	7.58
21	铝	mg/L	≤0.2	0.076	0.052	0.085
22	铁	mg/L	≤0.3	<0.05	<0.05	<0.05
23	锰	mg/L	≤0.1	<0.01	<0.01	<0.01
24	铜	mg/L	≤1.0	<0.01	<0.01	<0.01
25	锌	mg/L	≤1.0	<0.01	<0.01	<0.01
26	氯化物	mg/L	≤250	24.8	24.2	24.8
27	硫酸盐	mg/L	≤250	38.8	39.2	39.2
28	溶解性总固体	mg/L	≤1000	233	229	212
29	总硬度(以CaCO <sub>3</sub> 计)	mg/L	≤450	133	132	133
30	高锰酸盐指数(以O <sub>2</sub> 计)	mg/L	≤3	1.1	1.2	1.2
31	总α放射性	mg/L	≤0.5	<0.016	<0.016	<0.016
32	总β放射性	mg/L	≤1	0.060	0.064	0.055
33	游离氯	mg/L	0.3~2	0.50	0.70	0.80
34	一氯二溴甲烷	mg/L	≤0.1	<0.0020	<0.0020	<0.0020
35	二氯一溴甲烷	mg/L	≤0.06	0.0037	<0.0020	0.0024
36	三溴甲烷	mg/L	≤0.1	<0.0005	<0.0005	<0.0005
37	三卤甲烷		该类化合物中各种化合物的实测浓度与其各自限值的比值之和不超过1	0.20	0.07	0.12
38	三氯乙醛	mg/L	≤0.01	<0.0030	<0.0030	<0.0030
39	挥发性酚类(以苯酚计)	mg/L	≤0.002	<0.002	<0.002	<0.002
40	氨(以N计)	mg/L	≤0.5	<0.02	<0.02	<0.02
41	二氯甲烷	mg/L	≤0.02	<0.0020	<0.0020	<0.0020
42	三氯乙酸	mg/L	≤0.1	<0.025	<0.025	<0.025
43	二氯乙酸	mg/L	≤0.05	<0.025	<0.025	<0.025
44	甲醛	mg/L	≤0.9	<0.05	<0.05	<0.05
45	锑	mg/L	≤0.005	<0.0001	<0.00010	<0.00010

46	高氯酸盐	mg/L	0.07	0.00429	0.00513	0.00429
47	2,4,6-三氯酚	mg/L	≤0.2	<0.001	<0.001	<0.001
48	四氯化碳	mg/L	≤0.002	<0.0005	<0.0005	<0.0005
49	钡	mg/L	≤0.7	0.0534	0.057	0.045
50	铍	mg/L	≤0.002	<0.0004	<0.0004	<0.0004
51	硼	mg/L	≤1.0	<0.20	<0.20	<0.20
52	钼	mg/L	≤0.07	<0.0080	<0.008	<0.008
53	镍	mg/L	≤0.02	<0.0010	<0.001	<0.001
54	银	mg/L	≤0.05	<0.0010	<0.001	<0.001
55	铊	mg/L	≤0.0001	<0.00001	<0.000008	<0.000008
56	硒	mg/L	≤0.01	<0.0001	<0.0001	<0.0001
57	1,2-二氯乙烷	mg/L	≤0.03	<0.0020	<0.0020	<0.0020
58	氯乙烯	mg/L	≤0.001	<0.00100	<0.0010	48.09
59	1,1-二氯乙烯	mg/L	≤0.03	<0.0002	<0.0002	<0.0002
60	1,2-二氯乙烯(总量)	mg/L	≤0.05	<0.0020	<0.0020	<0.0020
61	三氯乙烯	mg/L	≤0.02	<0.0005	<0.0005	<0.0005
62	四氯乙烯	mg/L	≤0.04	<0.0020	<0.0020	<0.0020
63	六氯丁二烯	mg/L	≤0.0006	<0.0005	<0.0005	<0.0005
64	苯	mg/L	≤0.01	<0.0005	<0.0005	<0.0005
65	甲苯	mg/L	≤0.7	<0.0005	<0.0005	<0.0005
66	二甲苯(总量)	mg/L	≤0.5	<0.0030	<0.0030	<0.0030
67	苯乙烯	mg/L	≤0.02	<0.0005	<0.0005	<0.0005
68	氯苯	mg/L	≤0.3	<0.0020	<0.0020	<0.0020
69	1,4-二氯苯	mg/L	≤0.3	<0.0020	<0.0020	<0.0020
70	三氯苯(总量)	mg/L	≤0.02	<0.0150	<0.0150	<0.0150
71	六氯苯	mg/L	≤0.001	<0.0003	<0.0003	<0.0003
72	七氯	mg/L	≤0.0004	<0.0003	<0.0003	<0.0003
73	马拉硫磷	mg/L	≤0.25	<0.004	<0.004	<0.004
74	乐果	mg/L	≤0.006	<0.006	<0.006	<0.006
75	灭草松	mg/L	≤0.3	<0.00025	<0.00025	<0.00025
76	百菌清	mg/L	≤0.01	<0.0006	<0.0006	<0.0006
77	呋喃丹	mg/L	≤0.007	<0.0001	<0.0001	<0.0001
78	毒死蜱	mg/L	≤0.03	<0.0002	<0.0002	<0.0002
79	草甘膦	mg/L	≤0.7	<0.0250	<0.025	<0.025
80	敌敌畏	mg/L	≤0.001	<0.0005	<0.0005	<0.0005
81	莠去津	mg/L	≤0.002	<0.0005	<0.0005	<0.0005
82	溴氰菊酯	mg/L	≤0.02	<0.0020	<0.002	<0.002
83	2,4-滴	mg/L	≤0.03	<0.00025	<0.00025	<0.00025
84	五氯酚	mg/L	≤0.009	<0.001	<0.001	<0.001
85	苯并(α)芘	mg/L	≤0.00001	<0.0000014	<0.0000014	<0.0000014
86	邻苯二甲酸二(2-乙基己基)酯	mg/L	≤0.008	<0.0005	<0.0005	<0.0005
87	丙烯酰胺	mg/L	≤0.0005	<0.00015	<0.00015	<0.00015
88	环氧氯丙烷	mg/L	≤0.0004	<0.0002	<0.0002	<0.0002
89	微囊藻毒素LR	mg/L	≤0.001	<0.0001	<0.0001	<0.0001
90	钠	mg/L	≤200	17.83	17.53	18.57
91	阴离子表面活性剂	mg/L	≤0.3	0.028	0.027	<0.025
92	贾第鞭毛虫	个/10L	<1	/	0	0
93	隐孢子虫	个/10L	<1	/	0	0
94	★2-甲基异炭醇	mg/L	≤0.000010	/	<0.000005	<0.000005
95	★土溴素	mg/L	≤0.000010	/	<0.000005	<0.000005
96	★乙草胺	mg/L	<0.00002	/	<0.00002	<0.00002

备注：带★项目为委托项目